

Certified Validation Report Template, Part A: Provided by Validator

Audit Information:

Water System Name: South Feather Water & Power Agency - Miner's Ranch

Public Water System Identification (PWSID)¹: CA 0410006

¹List only 1 PWSID, which should match the PWSID on the FWAS Instructions Tab. For Special cases where multiple water systems are connected with permanent two-way interties, list those additional PWSIDs in the **Notes** below and describe the water distribution system(s) configuration.

PWSID and Water System Configuration Notes (Provided to Validator by Water System):

Audit Period: Calendar Year 2020

Validation Date: 9/22/2021

Sufficient Supporting Documents Provided: Yes

Validation Findings & Confirmation Statement:

Key Audit Metrics:

Data Validity Score: 66 Data Validity Band (Level): Band III (51-70)

ILI: 3.27 Real Loss: 74.98 gallons/
connection/day Apparent Loss: 39.11 gallons/
connection/day

Non-revenue water as percent of cost of operating system: 5.0%

Certification Statement by Validator:

This water loss audit report has been Level 1 validated per the requirements of California Code of Regulations Title 23, Division 2, Chapter 7 and the California Water Code Section 10608.34.

All recommendations on volume derivation and Data Validity Grades were incorporated into the water audit. ☐

If not, rejected recommendations are included here:

Validator Information:

Water Audit Validator: Allison Cronk

Qualifications: Water Audit Validator Certificate issued by the CA-NV Section of the AWWA

Validator Provided